

Comments on Sikeston Power Station:

EPA Comments:

None.

State Comments:

From: "Clay, Bob" <bob.clay@dnr.mo.gov>  
To: James Kohler/DC/USEPA/US@EPA  
Date: 07/08/2010 02:26 PM  
Subject: RE: Comment Request on EPA Draft Assessment Report for Sikestown Power Station

Jim,  
Thank you for including us on this. I have read the report and see nothing that particularly concerns me. Since the consultant did not seem to think there was a sense of urgency in repairing the slide gate valve operating stems, I presume this structure is not critical to the safety of the dikes. The recommendation for seismic stability analysis seems prudent. The analysis should include evaluation of liquefaction potential of the foundation soils. I do not think it is necessary for me to make any formal comments.

WATER RESOURCES CENTER  
Bob Clay, P.E.  
Chief Engineer, Dam and Reservoir Safety Program

-----Original Message-----

From: Kohler.James@epamail.epa.gov [mailto:Kohler.James@epamail.epa.gov]  
Sent: Wednesday, July 07, 2010 10:50 AM  
To: Cruise.Nicole@epamail.epa.gov; Clay, Bob  
Cc: Hoffman.Stephen@epamail.epa.gov  
Subject: Comment Request on EPA Draft Assessment Report for Sikestown Power Station

Dear Bob and Nicole:

We would like to offer Missouri and EPA Region 7 an opportunity to comment on the Draft Assessment Report for the facility below. You can access the report by following the link below. Please let me know if intend to comment. Thank you!

Jim

\*\*\*\*\*

Jim Kohler, P.E.

Environmental Engineer  
LCDR, U.S. Public Health Service  
U.S. Environmental Protection Agency  
Office of Resource Conservation and Recovery  
Phone: 703-347-8953  
Fax: 703-308-0514

\*\*\*\*\*

## Company Comments:

From: "Chester Cardwell" <ccard@sbmu.net>  
To: James Kohler/DC/USEPA/US@EPA  
Date: 07/29/2010 04:47 PM  
Subject: RE: Comment Request on EPA Draft Assessment Report for Sikeston Power Station

Mr. Jim Kohler, P.E,

After reviewing the report with plant staff there was only one comment.  
Our fly ash was pneumatically conveyed to the fly ash pond where it was  
discharged under water.

Thank you,  
Chester Cardwell  
Plant Manager

Office (573) 475-3112  
Mobile (573) 380-3611  
Plant (573) 471-5000  
Fax (573) 471-5003  
email ccard@sbmu.net  
Website: <http://www.sikestonbmu.org/sikestonpowerstation.htm>

Sikeston Power Station  
Board of Municipal Utilities  
1551 W. Wakefield Ave.  
PO. Box 370  
Sikeston, Missouri 63801-0370